

Determinand (Parameter)	Your Result	UK Legal Limit (PCV)	Status	Units
Total coliforms	63	0	✗ FAIL	MPN/100ml
E coli	2	0	✗ FAIL	MPN/100ml
Individual Pesticides (26 tested, e.g., 2,4-D, MCPA)	All below <0.027	0.10 per pesticide	PASS	ug/l
Volatile Organic Compounds (10 tested, e.g., Benzene)	All below <0.62	Varies (All within limits)	PASS	ug/l
Aluminium as Al	15.1	200	PASS	ug/l
Antimony as Sb	<0.027	5.0	PASS	ug/l
Arsenic as As	1.13	10	PASS	ug/l
Boron as B	<0.046	1.0	PASS	mg/l
Bromate as BrO3	<1.47	10	PASS	ug/l
Cadmium as Cd	<0.054	5.0	PASS	ug/l
Chromium as Cr	0.713	50	PASS	ug/l
Colour	<2.0	20	PASS	mg/l Pt/Co
Copper as Cu	<0.003	2.0	PASS	mg/l
Electrical Conductivity @ 20°C	361	2500	PASS	uS/cm
Fluoride as F	0.173	1.5	PASS	mg/l
Hydrogen Ion (pH)	7.3	6.5 – 9.5	PASS	pH value
Iron as Fe	48.1	200	PASS	ug/l